

STATE OF MISSOURI  
**DEPARTMENT OF NATURAL RESOURCES**

MISSOURI CLEAN WATER COMMISSION



**MISSOURI STATE OPERATING PERMIT**

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended,

Permit No. MO-0111511

Owner: Purina Mills, LLC  
Address: 1401 South Hanley Road, St. Louis, MO 63144

Continuing Authority: Same as above  
Address: Same as above

Facility Name: Purina Mills, LLC  
Address: 4225 South 169 Highway, St. Joseph, MO 64503

Legal Description: SW  $\frac{1}{4}$ , NE  $\frac{1}{4}$ , Sec. 26, T57N, R35W, Buchanan County

Receiving Stream: Tributary to Platte River (U)  
First Classified Stream and ID: Platte River (P)(00312)  
USGS Basin & Sub-watershed No.: (10240012-080005)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

**FACILITY DESCRIPTION**

Outfall #001 - Industry - SIC #2048

Stormwater runoff.

Design flow is 0.216 MGD.

Actual flow is dependent upon precipitation.

Outfall #002 - Industry - SIC #2048

Stormwater runoff.


Design flow is 0.72 MGD.

Actual flow is dependent upon precipitation.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

August 23, 2002

Effective Date

  
Stephen M. Mahford, Director, Department of Natural Resources  
Executive Secretary, Clean Water Commission

August 22, 2007

Expiration Date  
MO 780-0041 (10-93)

Jim Hull, Director of Staff, Clean Water Commission

| <b>A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS</b>   |        |                            |                   |                    | PAGE NUMBER 2 of 3       |                    |
|--|--------|----------------------------|-------------------|--------------------|--------------------------|--------------------|
|  |        |                            |                   |                    | PERMIT NUMBER MO-0111511 |                    |
| The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below: |        |                            |                   |                    |                          |                    |
| OUTFALL NUMBER AND EFFLUENT<br>PARAMETER(S)  | UNITS  | FINAL EFFLUENT LIMITATIONS |                   |                    | MONITORING REQUIREMENTS  |                    |
|  |        | DAILY<br>MAXIMUM           | WEEKLY<br>AVERAGE | MONTHLY<br>AVERAGE | MEASUREMENT<br>FREQUENCY | SAMPLE<br>TYPE     |
| <u>Outfalls #001 &amp; #002</u>  |        |                            |                   |                    |                          |                    |
| Flow   | MGD    | *                          |                   | *                  | once/month               | 24 hr.<br>estimate |
| Biochemical Oxygen Demand <sub>5</sub>   | mg/L   | 60                         |                   | 45                 | once/month               | grab               |
| Total Suspended Solids   | mg/L   | 70                         |                   | 50                 | once/month               | grab               |
| pH - Units   | SU     | **                         |                   | **                 | once/month               | grab               |
| Chemical Oxygen Demand   | mg/L   | 120                        |                   | 90                 | once/month               | grab               |
| Oil & Grease   | mg/L   | 15                         |                   | 10                 | once/month               | grab               |
| Rainfall   | inches | *                          |                   | *                  | once/day                 | daily total        |
| MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>October 28, 2002</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.   |        |                            |                   |                    |                          |                    |
| <b>B. STANDARD CONDITIONS</b>  |        |                            |                   |                    |                          |                    |
| IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Part I</u> STANDARD CONDITIONS DATED <u>October 1, 1980</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.   |        |                            |                   |                    |                          |                    |

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- \* Monitoring requirement only.
- \*\* pH is measured in pH units and is not to be averaged. The pH is to be maintained at or above 6.0 pH units.

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
  - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
    - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - (2) controls any pollutant not limited in the permit.
  - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
  - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.
2. All outfalls must be clearly marked in the field.

C. SPECIAL CONDITIONS (continued)

3. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
  - (1) One hundred micrograms per liter (100 µg/L);
  - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
  - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
  - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.

4. Report as no-discharge when a discharge does not occur during the report period.

5. General Criteria. The following water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:

- (a) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
- (b) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
- (c) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
- (d) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
- (e) There shall be no significant human health hazard from incidental contact with the water;
- (f) There shall be no acute toxicity to livestock or wildlife watering;
- (g) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
- (h) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

6. The permittee shall take a sample for every stormwater runoff event not to exceed once per month.